



90 Sargent Drive • New Haven, Connecticut 06511-5966
203-401-6743 or 877-894-5773 (Telephone) • Website: www.rwater.com

Laboratory Certification IDs

CT: PH-0411, NH: 2239, NY: 11867, PA: 68-05519, RI: LAO00339, MA: M-CT004

Certified analyte list is available at: www.rwalab.com

Client:


Bill Cookerly and Noreen Jordan
Randolph-Holbrook Joint Water
50 N. Franklin Street

Holbrook, MA 02343
617-470-1624 cookerlyb@gmail.com
781-767-1800 NJordan
NJordan@Holbrookmassachusetts.us

ANALYTICAL REPORT

Project: FEE-RANDOLPHHOLBROOK-22-000007

Report Date: 8/7/2022



This Laboratory is in compliance with the NELAP requirements of procedures used except where indicated.
This report contains results for the analysis tested, under the sampling conditions described on the Chain Of Custody (COC), as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

The COC form has been scanned to accompany the analytical report and is an exact copy of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact RWA Client Services at (203) 401-6743 or (877) 894-5773. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

A handwritten signature in cursive script that reads "Gary M. Alexander".

Gary M. Alexander, Team Lead
Technical Representative

Sample ID: 300208042

Customer ID: FINISHED WATER

Collection Date: 07/05/2022 12:00

PWS ID# / LOC ID#: 4244001 / 10296

Project: FEE-RANDOLPHHOLBROOK-22-000007

Analyte	CAS#	Results	MDL	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
PFBS	375-73-5	2.60	0.89	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFHxA	307-24-4	3.46	0.68	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFHpA	375-85-9	2.10	0.62	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFHxS	355-46-4	2.55	0.90	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFOA	335-67-1	4.34	0.72	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFOS	1763-23-1	7.70	0.89	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFNA	375-95-1	1.03	0.63	2.0	ng/L	1.0	J	EPA537	7/16/22 0018	CSS
PFDA	335-76-2	ND	0.72	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFUnA	2058-94-8	ND	0.91	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
NMeFOSAA	2355-31-9	ND	1.19	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
NEtFOSAA	2991-50-6	ND	1.03	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFDaA	307-55-1	ND	0.83	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFTTrDA	72629-94-8	ND	0.90	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFTA	376-06-7	ND	0.97	2.0	ng/L	1.0		EPA537	7/16/22 0018	CSS
PFAS6 (MassDEP)		16.69	2.00	2.00	ng/L					
Surrogates				Results	Recovery Limits		Pass/Fail			
13C-PFHxA (SUR) % Recovery				98.44	70 - 130		Pass			
13C-PFDA (SUR) % Recovery				88.36	70 - 130		Pass			
d5-NEtFOSAA (SUR) % Recovery				74.55	70 - 130		Pass			

Sample Extraction Data:

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300208042	PFAS_537	537_EXT-220711-1	250	07/11/2022

Sample ID: 300208040

Customer ID: RAW WATER

Collection Date: 07/05/2022 12:00

PWS ID# / LOC ID#:

Project: FEE-RANDOLPHHOLBROOK-22-000007

Analyte	CAS#	Results	MDL	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
PFBS	375-73-5	2.24	0.89	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFHxA	307-24-4	2.90	0.68	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFHpA	375-85-9	1.63	0.62	2.0	ng/L	1.0	J	EPA537	7/15/22 2353	CSS
PFHxS	355-46-4	2.44	0.90	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFOA	335-67-1	3.97	0.72	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFOS	1763-23-1	7.12	0.89	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFNA	375-95-1	0.79	0.63	2.0	ng/L	1.0	J	EPA537	7/15/22 2353	CSS
PFDA	335-76-2	ND	0.72	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFUnA	2058-94-8	ND	0.91	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
NMeFOSAA	2355-31-9	ND	1.19	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
NEtFOSAA	2991-50-6	ND	1.03	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFDaA	307-55-1	ND	0.83	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFTTrDA	72629-94-8	ND	0.90	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFTA	376-06-7	ND	0.97	2.0	ng/L	1.0		EPA537	7/15/22 2353	CSS
PFAS6 (MassDEP)		13.53	2.00	2.00	ng/L					
Surrogates		Results		Recovery Limits		Pass/Fail				
13C-PFHxA (SUR) % Recovery		81.42		70 - 130		Pass				
13C-PFDA (SUR) % Recovery		77.60		70 - 130		Pass				
d5-NEtFOSAA (SUR) % Recovery		82.24		70 - 130		Pass				

Sample Extraction Data:

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300208040	PFAS_537	537_EXT-220711-1	250	07/11/2022