



90 Sargent Drive • New Haven, Connecticut 06511-5966
203-401-6743 or 877-894-5773 (Telephone) • Website: www.rwater.com

Laboratory Certification IDs

CT: PH-0411, NH: 2239, NY: 11867, PA: 68-05519, RI: LAO00339, MA: M-CT004

Certified analyte list is available at: www.rwalab.com

Client: Bill Cookerly and Noreen Jordan
Randolph-Holbrook Joint Water
50 N. Franklin Street

Holbrook, MA 02343
617-470-1624 cookerlyb@gmail.com
781-767-1800 NJordan
NJordan@Holbrookmassachusetts.us

ANALYTICAL REPORT

Project: FEE-RANDOLPHHOLBROOK-22-000010

Report Date: 10/18/2022

Sept
Raw 19.61
Finished 19.79

This Laboratory is in compliance with the NELAP requirements of procedures used except where indicated .
This report contains results for the analysis tested, under the sampling conditions described on the Chain Of Custody (COC), as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

The COC form has been scanned to accompany the analytical report and is an exact copy of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact RWA Client Services at (203) 401-6743 or (877) 894-5773. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Gary M. Alexander, Team Lead

Technical Representative

Sample ID: 300241755

Customer ID: Raw Water

Collection Date: 09/08/2022 12:00

PWS ID# / LOC ID#:

Project: FEE-RANDOLPHHOLBROOK-22-000010

Analyte	CAS#	Results	MDL	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
PFBS	375-73-5	2.81	0.89	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFHxA	307-24-4	4.23	0.68	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFHpA	375-85-9	2.50	0.62	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFHxS	355-46-4	2.60	0.90	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFOA	335-67-1	5.67	0.72	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFOS	1763-23-1	8.84	0.89	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFNA	375-95-1	1.08	0.63	2.0	ng/L	1.0	J	EPA537	9/21/22 1709	CSS
PFDA	335-76-2	ND	0.72	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFUnA	2058-94-8	ND	0.91	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
NMeFOSAA	2355-31-9	ND	1.19	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
NEtFOSAA	2991-50-6	ND	1.03	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFDaA	307-55-1	ND	0.83	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFTDA	72629-94-8	ND	0.90	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFTA	376-06-7	ND	0.97	2.0	ng/L	1.0		EPA537	9/21/22 1709	CSS
PFAS6 (MassDEP)		19.61	2.00	2.00	ng/L					
Surrogates		Results		Recovery Limits		Pass/Fail				
13C-PFHxA (SUR) % Recovery		97.64		70 - 130		Pass				
13C-PFDA (SUR) % Recovery		87.77		70 - 130		Pass				
d5-NEtFOSAA (SUR) % Recovery		77.85		70 - 130		Pass				

Sample Extraction Data:

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300241755	PFAS_537	537_EXT-220916-1	250	09/16/2022

Sample ID: 300241757

Customer ID: Finished Water

Collection Date: 09/08/2022 12:00

PWS ID# / LOC ID#: 4244001 / 10296

Project: FEE-RANDOLPHHOLBROOK-22-000010

Analyte	CAS#	Results	MDL	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
PFBS	375-73-5	2.52	0.89	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFHxA	307-24-4	4.32	0.68	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFHpA	375-85-9	2.73	0.62	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFHxS	355-46-4	2.60	0.90	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFOA	335-67-1	5.64	0.72	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFOS	1763-23-1	8.82	0.89	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFNA	375-95-1	1.20	0.63	2.0	ng/L	1.0	J	EPA537	9/21/22 1734	CSS
PFDA	335-76-2	ND	0.72	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFUnA	2058-94-8	ND	0.91	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
NMeFOSAA	2355-31-9	ND	1.19	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
NEtFOSAA	2991-50-6	ND	1.03	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFDaA	307-55-1	ND	0.83	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFTTrDA	72629-94-8	ND	0.90	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFTA	376-06-7	ND	0.97	2.0	ng/L	1.0		EPA537	9/21/22 1734	CSS
PFAS6 (MassDEP)		19.79	2.00	2.00	ng/L					
Surrogates		Results		Recovery Limits		Pass/Fail				
13C-PFHxA (SUR) % Recovery		95.33		70 - 130		Pass				
13C-PFDA (SUR) % Recovery		82.44		70 - 130		Pass				
d5-NEtFOSAA (SUR) % Recovery		80.80		70 - 130		Pass				

Sample Extraction Data:

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300241757	PFAS_537	537_EXT-220916-1	250	09/16/2022