

Laboratory Certification IDs

CT: PH-0411 NH: 2239, NY: 11867, PA: 68-05519, VT: VT-11867, RI: LAO00339, MA: M-CT004

See website, www.rwalab.com/raw-lab-certifications, for certified analyte list

Client: Bill Cookerly and Noreen Jordan
Randolph-Holbrook Joint Water
50 N. Franklin Street

Holbrook, MA 02343
617-470-1624 cookerlyb@gmail.com
781-767-1800 NJordan
NJordan@Holbrookmassachusetts.us

ANALYTICAL REPORT

RWA: FEE-RANDOLPHHOLBROOK-21-000003

Report Date: 1/19/2022

December
14.52

This Laboratory is in compliance with the NELAP requirements of procedures used except where indicated .
This report contains results for the analysis tested, under the sampling conditions described on the Chain Of Custody (COC), as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

The COC form has been scanned to accompany the analytical report and is an exact copy of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact RWA Client Services at (203) 401-6743 or (877) 894-5773. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Technical Representative

Date Received: 12/23/2021

Text ID: NONE-300123900

Sample ID: 300123900

Customer ID: FINISHED WATER

Collection Date: 12/22/2021 10:00

	Analyte	Results	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
	PFBS	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
	PFHxA	3.47	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
1	PFHpA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
2	PFHxS	2.78	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
3	PFOA	4.59	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
4	PFOS	7.15	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
5	PFNA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
6	PFDA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
	PFUnA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
	NMeFOSAA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
	NEtFOSAA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
	PFDoA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
	PFTTrDA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA
	PFTA	ND	2	ng/L	1		EPA537	1/15/22 0:22	CSS/GMA

Surrogates	Results	Recovery Limits	Pass/Fail
13C-PFHxA (SUR) % Recovery	85.88	70 - 130	Pass
13C-PFDA (SUR) % Recovery	87.16	70 - 130	Pass
d5-NEtFOSAA (SUR) % Recovery	79.45	70 - 130	Pass

Sample Extraction Data:

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300123900	PFAS_537	537_EXT-220104-1	250	01/04/2022

Result Page:

Date Received: 12/23/2021

Text ID: NONE-300123898

Sample ID: 300123898

Customer ID: RAW WATER

Collection Date: 12/22/2021 10:00

Analyte	Results	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
PFBS	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFHxA	3.08	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFHpA	2.08	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFHxS	2.06	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFOA	4.26	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFOS	8.29	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFNA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFDA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFUnA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
NMeFOSAA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
NEtFOSAA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFDaA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFTTrDA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA
PFTA	ND	2.02	ng/L	1.01		EPA537	1/14/22 23:56	CSS/GMA

Surrogates	Results	Recovery Limits	Pass/Fail
13C-PFHxA (SUR) % Recovery	83.00	70 - 130	Pass
13C-PFDA (SUR) % Recovery	101.01	70 - 130	Pass
d5-NEtFOSAA (SUR) % Recovery	85.31	70 - 130	Pass

Sample Extraction Data:

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300123898	PFAS_537	537_EXT-220104-1	248	01/04/2022