

PFAS**Submitted - Signed**

PWS ID #: 4133002

City/Town: HOLBROOK

PWS Name: BLUEDROP WATER @ STANNEYS VENDING

PWS Class: TNC

Primary Lab MA Cert #: MA030 Primary Lab Name: ALPHA ANALYTICAL

Location ID	Location	M/S:	D/S:	R/F:	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection
10000	DISPENSING NOZZLE	S	D		RS	James MacLane	4/26/2022	O		
Sample Comments:		Lab Sample ID:		Sample Composted:		Composite Sample Comments:				
		L2222419-01		N						
Analytical Method:	Analytical Lab ID:	Analytical Lab:		Analysis Date:		Extraction date:	Analysis Comments:			
EPA 537.1	MA030	ALPHA ANALYTICAL		5/7/2022		5/6/2022				
QA/QC Method1:		QA/QC Result1:		QA/QC Method 2:		QA/QC Result 2:				
PERFLUORO-N(1,2-13C2)HEXANOIC ACID (13C-PFHXA)		115		2,3,3,3-TETRAFLUORO-2-(1,1,2,2,3,3,3-HEPTAFLUOROPROPPOXY)-13C3-PROPANOIC ACID (M3HFPD-DA)		120		QA/QC Result4:		
QA/QC Method3:		QA/QC Result3:		QA/QC Method4:		QA/QC Result4:				
PERFLUORO-N(1,2-13C2)DECANOIC ACID (13C-PFDA)		91		N-DEUTERIOETHYLPERFLUORO-1-OCTANESULFONAMIDOACETIC ACID (D5-NETFOSAA)		93				

CAS #	Contaminant:	Result:	UOM:	MCL (ORSG):	MDL:	MRL:	Dilution Factor	Result Qualifier:	Result Qualifier Description
Regulated Contaminants									
335-76-2	PERFLUORODECANOIC ACID - PFDA	ND	NG/L		0.643	2.00	1		
375-85-9	PERFLUOROHEPTANOIC ACID-PFHPA	ND	NG/L		0.643	2.00	1		
355-46-4	PERFLUOROHEXANESULFONIC ACID-PFHXS	ND	NG/L		0.643	2.00	1		
375-95-1	PERFLUORONONANOIC ACID-PFNA	ND	NG/L		0.643	2.00	1		
1763-23-1	PERFLUOROOCTANESULFONIC ACID-PFOS	ND	NG/L		0.643	2.00	1		
335-67-1	PERFLUOROOCTANOIC ACID-PFOA	ND	NG/L		0.643	2.00	1		
NONE	PFAS6	ND	NG/L	20	0.643	2.00	1		
Unregulated Contaminants									
763051-92-9	11-CHLOROECOSAFLUORO-3-	ND	NG/L		0.643	2.00	1		

M/S = Multiple or Single sources represented in sample site.

D/S = Distribution or Source sample site.

R/F = Raw or Finished water sample site.

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4133002
PWS Name: BLUEDROP WATER @ STANNEYS VENDING5/19/2022 1:33:54 PM
Page 1 of 2

PFA's

Submitted - Signed

919005-14-4	OXAUINDECANE-1-SULFONIC ACID-11CL-PF3OU DS	ND	NG/L	0.643	2.00	1
756426-58-1	4,8-DIOXA-3H-PERFLUORONONANOIC ACID - ADONA	ND	NG/L	0.643	2.00	1
13252-13-6	9-CHLOROHEXADECACFLURO-3-OXANONE-1-SULFONIC ACID-9CL-PF3ONS	ND	NG/L	0.643	2.00	1
2991-50-6	HEXAFLUOROPROPYLENE OXIDE DIMER ACID - HFPO-DA	ND	NG/L	0.643	2.00	1
2355-31-9	N-ETHYL PERFLUOROOCTANESULFONAMIDOACET IC ACID - NETFOSAA	ND	NG/L	0.643	2.00	1
375-73-5	N-METHYL PERFLUOROOCTANESULFONAMIDOACET IC ACID - NMEFOSAA	ND	NG/L	0.643	2.00	1
307-55-1	PERFLUOROBUTANESULFONIC ACID-PFBS	ND	NG/L	0.643	2.00	1
307-24-4	PERFLUORODODECANOIC ACID - PFDOA	ND	NG/L	0.643	2.00	1
376-06-7	PERFLUOROHXANOIC ACID - PFHXA	ND	NG/L	0.643	2.00	1
72629-94-8	PERFLUOROTETRADECANOIC ACID - PFTA	ND	NG/L	0.643	2.00	1
2058-94-8	PERFLUOROTRIDECANOIC ACID - PFTDA	ND	NG/L	0.643	2.00	1
	PERFLUOROUNDECANOIC ACID - PFUNA	ND	NG/L	0.643	2.00	1

Primary Lab Signature: Joseph Watkins

Date: 5/19/2022

EDEP Transaction ID: 1373249

Certified Signer User Name: JLVATKINS

M/S = Multiple or Single sources represented in sample site.

D/S = Distribution or Source sample site.

R/F = Raw or Finished water sample site.

MDL = Method Detection Limit.

UOM = Unit of Measurement.

PWS ID #: 4133002

PW/S Name: BLUEDROP WATER@

STANNEYS VENDING

5/19/2022 1:33:54 PM

Page 2 of 2