

# Regional Water Authority

90 Sargent Drive • New Haven, Connecticut 06511-5966  
203-401-6743 or 877-894-5773 (Telephone) • Website: [www.rwater.com](http://www.rwater.com)

## Laboratory Certification IDs

CT: PH-0411, NH: 2239, NY: 11867, PA: 68-05519, RI: LAO00339, MA: M-CT004  
See website, [www.rwalab.com/rwa-lab-certifications](http://www.rwalab.com/rwa-lab-certifications), for certified analyte list.

**Client:** Bill Cookerly and Noreen Jordan  
Randolph-Holbrook Joint Water  
50 N. Franklin Street  
  
Holbrook, MA 02343  
617-470-1624 cookerlyb@gmail.com  
781-767-1800 NJordan  
NJordan@Holbrookmassachusetts.us

## ANALYTICAL REPORT

RWA: FEE-RANDOLPHHOLBROOK-22-000004

Report Date: 6/9/2022

15.65

This Laboratory is in compliance with the NELAP requirements of procedures used except where indicated .  
This report contains results for the analysis tested, under the sampling conditions described on the Chain Of Custody (COC ), as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

The COC form has been scanned to accompany the analytical report and is an exact copy of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact RWA Client Services at (203) 401-6743 or (877) 894-5773. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Gary M. Alexander, Team Lead  
Technical Representative

# Regional Water Authority

90 Sargent Drive • New Haven, Connecticut 06511-5966  
 203-401-6743 or 877-894-5773 (Telephone) • Website: www.rwater.com

**Result Page:**

Date Received: 04/21/2022                      Customer ID: RAW WATER  
 Sample ID: 300173555                            PWS ID#:  
 Collection Date: 04/20/2022 11:00            LOC ID#:

Analyte	CAS#	Results	MDL	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
PFBS	375-73-5	2.24	0.89	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFHxA	307-24-4	3.12	0.68	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFHpA	375-85-9	2.18	0.62	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFHxS	355-46-4	1.61	0.90	2	ng/L	1	J	EPA537	5/4/22 0340	CSS
PFOA	335-67-1	4.43	0.72	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFOS	1763-23-1	6.88	0.89	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFNA	375-95-1	0.82	0.63	2	ng/L	1	J	EPA537	5/4/22 0340	CSS
PFDA	335-76-2	ND	0.72	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFUnA	2058-94-8	ND	0.91	2	ng/L	1		EPA537	5/4/22 0340	CSS
NMeFOSAA	2355-31-9	ND	1.19	2	ng/L	1		EPA537	5/4/22 0340	CSS
NEtFOSAA	2991-50-6	ND	1.03	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFDoA	307-55-1	ND	0.83	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFTTrDA	72629-94-8	ND	0.90	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFTA	376-06-7	ND	0.97	2	ng/L	1		EPA537	5/4/22 0340	CSS
PFAS6 (MassDEP)		13.49	2.00	2	ng/L					
	Surrogates		Results		Recovery Limits				Pass/Fail	
	13C-PFHxA (SUR) % Recovery		104.78		70 - 130				Pass	
	13C-PFDA (SUR) % Recovery		106.72		70 - 130				Pass	
	d5-NEtFOSAA (SUR) % Recovery		89.16		70 - 130				Pass	

**Sample Extraction Data:**

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300173555	PFAS_537	537_EXT-220427-1	250	04/27/2022

# Regional Water Authority

90 Sargent Drive • New Haven, Connecticut 06511-5966  
 203-401-6743 or 877-894-5773 (Telephone) • Website: www.rwater.com

Date Received: 04/21/2022  
 Sample ID: 300173557  
 Collection Date: 04/20/2022 11:00

Customer ID: FINISHED WATER  
 PWS ID#: 4244001  
 LOC ID#: 10296

Analyte	CAS#	Results	MDL	RL	Units	Dilution	Qualifier	Method	Date Time/ Analyzed	Analyst
PFBS	375-73-5	2.35	0.93	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFHxA	307-24-4	3.52	0.71	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFHpA	375-85-9	2.28	0.65	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFHxS	355-46-4	2.42	0.95	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFOA	335-67-1	4.43	0.76	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFOS	1763-23-1	6.52	0.93	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFNA	375-95-1	0.94	0.66	2.1	ng/L	1.05	J	EPA537	5/2/22 2322	CSS
PFDA	335-76-2	ND	0.76	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFUnA	2058-94-8	ND	0.96	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
NMeFOSAA	2355-31-9	ND	1.25	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
NEtFOSAA	2991-50-6	ND	1.08	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFDoA	307-55-1	ND	0.87	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFTTrDA	72629-94-8	ND	0.95	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFTA	376-06-7	ND	1.02	2.1	ng/L	1.05		EPA537	5/2/22 2322	CSS
PFAS6 (MassDEP)		15.65	2.10	2.1	ng/L					
Surrogates										
			Results	Recovery Limits		Pass/Fail				
13C-PFHxA (SUR) % Recovery			116.05	70 - 130		Pass				
13C-PFDA (SUR) % Recovery			96.39	70 - 130		Pass				
d5-NEtFOSAA (SUR) % Recovery			85.57	70 - 130		Pass				

**Sample Extraction Data:**

Lab Number (Field ID)	Prep Method	Batch	Final (mL)	Date
300173557	PFAS_537	537_EXT-220427-1	238	04/27/2022